SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Pruitt Development OWNER:__ AGENT:__ PHONE:__
ADDRESS:__ APPLICATION DATE:__ DATE EVALUATED:__
PROPOSED FACILITY:__
PROPERTY SIZE:__
LOCATION OF SITE: Lot 17 wintward
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring___ Pit___ Cu

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZ LTA
1	Nose 10%	0 to 5	L GR		PS	PS	PS	N/A	.35
		5 to 30	C SBK	SEAP SS SP					
		30 to 48	SCL WSBK	NEAP NS NP					
2	Nose to Linear 17%	0 to 6	L GR		PS	PS	PS	PS	.25
		6 to 42	C SBK	SEAP SS SP					
		42 to 48	C - Saprolite						
3									
4									
5									

SITE LONG-TERM ACCEPTANCE RATE: 1.28

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J.C. Moore OTHER(S) PRESENT:__
COMMENTS:__