DIVISION OF ENVIRONMENTAL HEALTH, AND NATURAL RESOURCES
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jerry Hawkins
ADDRESS: ___ APPLICANT: ___
PROPOSED FACILITY: ___ APPLICATION DATE: ___ DATE EVALUATED: 12-15
LOCATION OF SITE: Lot 32 Palomino Park PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 2%	0-9	gr sl sb	vfr fr					
		9-30	sbk fr	vfr fr					
		30-48	w/ sbk str	vfr fr	5YR 5/8				.3
			w/ common Rg-w relic mottles						
2	LSS 2%	0-6	gr sl sb	vfr fr					
		6-32	sbk sc	vfr fr 5YR					
		32-48	sbk sc	vfr fr 5YR					.3
			few relic mottles beginning @ 14"+						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	18	18
System Type(s)	Conv.	Conv.
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___