IREDELL COUNTY HEALTH DEPARTMENT 4649 986421

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rocky D. Helms DATE 8/15/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115-21 N. TL 1312 (Flower House LP.) TL 1311 (Rankin Hill) TL Palomino Park TL Sorrel At end.

SUBDIVISION NAME Palomino Park LOT NO. 34 SECTION OR BLOCK NO. _____ S. R. No. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area _____

Character & Porosity of Soil Clay
Percolation Rate ~.35 gpd/ft²
Topography 4-6%
Depth to Water Table 4'+
Rock or other impervious formations none observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by W. Eller

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

ROVEMENTS PERMIT BY _____

IMENTS: _____

IFICATE OF COMPLETION BY Andrew C. Price DATE 8/15/88

ING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making
ements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink

08319

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rocky D. Helms DATE July 25, '88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115-21 N. R 1312 (Flower House Lp.) R 1311 (Rankin Hall Rd.) R Salomino Park R Sorrell Cove at end S. R. No. _____


SUBDIVISION NAME Salomino Park LOT NO. 34 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	35	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4 6 9	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	Depth to Water Table	47	
Lot Area 2 3/4 Ac			Rock or other impervious formations	none obs.	

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ~~X~~ Rocky D. Helms

IMPROVEMENTS PERMIT BY _____ DR Hunsucker RS

COMMENTS: Follow contour with drainfield. Install drainfield at a depth of 24" to bottom of ditch, 12" cover.

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold