IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 550. Paid MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13684 PIN# 4654095~~8~~~~7~~191 DATE 11/2/06

OWNER OR APPLICANT Burke Builders (Pat Burke) PHONE: Business 361-0047 Home

ADDRESS PO Box 3481 Mooresville 28115

LOCATION Hwy 115 South, Rt Bridges Farm Rd, property on Lt across from Davidson Estates 195 Bridge Farm

SUBDIVISION Bridges Farm BLOCK / SECTION LOT LOT AREA 1.24 Acre SITE CLASS. P.S. DESIGN FLOW 240GPD L.T.A.R. .3 JWIT / .25 REPAIR

Septic Tank: 1000 Gallons; STB 1012 Date 1-16-07

Pump Tank: 1000 Gallons; PT 19 Date 2-22-07

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 600 Linear Feet 200

No Lines 4 Trench Width 36" Max Trench Bottom Depth ~~24~~ 18"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: PM - 25% Reduction

Repair System Description: PBPS Pressure

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 4 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions:

INITIAL SITE SKETCH

See plans from S&EC (ATTACHED)

AS BUILT SKETCH

- Lines, Tanks, PM checked 6-5-07 jm
- Supply line sleeved in ductile iron through Gas line easement per Williams Co. request

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 11/07/06 Installed by: C+S Grading

Improvement Permit by: Jph E Alpe date 11/2/06 Operation Permit by: Wesley Sparks R.S. date 8/8/07

Authorization to Construct by: Jph E Alpe date 2-1-07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK