IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Debbie Pierce DATE June 13, '90 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 S. on left at jct. with 1138 (Presbyterian Rd.) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ B Yes (✓) No ( )

Lot Area Existing

Character & Porosity of Soil clay


Percolation Rate 2.3 to 35

Topography 2%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 690+ Linear Ft. 230+

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Little Hawkins

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: 58 Ex Well

SR 1138

CERTIFICATE OF COMPLETION BY D R Hinson, EHS DATE 6-13-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold