IREDELL COUNTY HEALTH DEPARTMENT 4654-27-8523

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herbert E. Tennant DATE 4-25-84 PERMIT NO. 116

PHONE: Business _____ Home _____


LOCATION 1155 on left on Corner of 1138 (Presbyterian Road)
110 Presbyterian Rd S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 3 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (X) Other 24 SEAT TAVERN

No. Bedrooms _____ No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes ( ) No (X)
Auto. Wash. Machine Yes ( ) No (X)
Site Suitable Yes ( ) No ( )
Lot Area 1.75 ACRE

Character & Porosity of Soil Clay
Percolation Rate 0.4 gal/ft²/day
Topography 2-6%
Depth to Water Table 4
Rock or other impervious formations None obs.



Plot of System

1000 gal Septic Tank
Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by J. J. Erwin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 4-25-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold