4654292740

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR [redacted] Joseph Fish DATE 9/19/79 PERMIT NO. 325

PHONE: Business _____ Home _____

LOCATION 1155 on left before Midway Lake Road


S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay-loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 Mpi
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-8%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unknown
Lot Area ~1 acre			Rock or other impervious formations	None observed



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by J. J. Erwin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clement/DAH DATE 9/19/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold