IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-6828 COPY

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 160590 PIN # 4654-49-0133 DATE MAY 12, 2010

OWNER or APPLICANT WOODLAWN SCHOOL PHONE: Business 704-987-9002 Home: 704-938-3474

OWNER or APPLICANT ADDRESS 193 PRESBYTERIAN CH ROAD, MOORESVILLE, 28115

LOCATION / DIRECTIONS US 21 SOUTH, TL PRESBYTERIAN RD, TL WOODLAWN SCHOOL LOOP, CH

SUBDIVISION BLOCK / SECTION LOT # LOT AREA 57.36 ac DESIGN FLOW 750 L.T.A.R. 0.30 GPD/FT²

Septic Tank 1500 Gallons: STB 444 Date 5-18-10

Pump Tank 1500 Gallons: PT 477 Date 4-27-10

Pump Make Goulds Model WE0712HV Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 628

Trench Width 36" Max. Trench Bottom Depth 24" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type I II III IV V(b)

System Description: 25% REDUCTION, PRESS. MAN.

Repair System Description: 25% REDUCTION, PRESS. MAN.

Maintenance Agreement Required ☑ YES ☐ NO

☐ GRAVITY ☑ PRESSURE

☐ Residence No. Bedrooms

☐ Business No. Persons

☑ Other SCHOOL No. Employees 75

☑ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply ☑ Private WELLS ☐ Public ☐ Community

Comments / Conditions

Comments / Conditions Filter Installed in ST
9/29/2010 Checked tank, lines & Pres. Manifold
11/1/2010 24# pressure set.
4 floats set

INITIAL SITE SKETCH

SEE ATTACHED "FAST TRACK" PLAN PREPARED BY SOIL & ENVIRONMENTAL CONSULTANTS, PA, PROJECT # 11441

A CONTRACT SHALL BE EXECUTED BETWEEN THE SYSTEM OWNER & A MANAGEMENT ENTITY PRIOR TO THE ISSUANCE OF AN OPERATION PERMIT (SYSTEM CLASS - TYPE V(b))

AS-BUILT SKETCH

Installed Quick 4 wide

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☑ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 5/20/10

Improvement Permit by: STEVE HEDRICK Date 5/12/10

Authorzation to Construct by: STEVE HEDRICK Date 5/12/10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: C. Wayne Robison

Operation Permit by: Maria W. Robison Date: 8/23/2010

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant