NCDENR
North Carolina Department of Environment and Natural Resources
Division of Environmental Health

Beverly Eaves Perdue
Governor

Terry L. Pierce
Director

Dee Freeman
Secretary

July 8, 2010

Mr. Bradley H. Bucy, PE
Hobbs, Upchurch & Associates, PA
9140 Arrowpoint Blvd., Ste. 120
Charlotte, NC 28273

Re: Water System Improvements
Woodlawn School Water System
Iredell County
I.D. # 20-49-007
Tracking # 10-00545

Dear Mr. Bucy:

We have received plans for the above referenced project. Additional information is required for the project review:

1. Please provide us the copies of all previous approved letters on 2002.
2. Existing and proposed water mains and sanitary sewer lines for all buildings in campus must be clearly depicted on drawing.
3. Where are the existing water treatment facility and storage tank(s) located? They must be depicted clearly on drawing.
4. Proposed reduced pressure backflow preventer must be specified and approved by USC or ASSE.

Based on the above comments, revisions are necessary. If no response is received within 180 days from the date on this letter, this project will be deactivated and withdrawn from our review process and the documents recycled.

When a project is deactivated, new documents have to be resubmitted in triplicate in accordance with Section T15A: 18C .0302 of the Rules Governing Public Water Systems in North Carolina.

If you have any questions, please feel free to call us at 919-733-2460 or visit our web site at http://ncdrinkingwater.state.nc.us/.

Sincerely,

Heinrich S. Ou
Technical Services Branch
Public Water Supply Section

HSO: db
cc: Britt Setzer, Regional Engineer
Iredell County Health Department
Dwayne Bowman, Owner