3:30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dale Stone DATE 5-5-87 PERMIT NO.

PHONE: Business Home

LOCATION 1155 TR 1138 (Presbyterian Rd) ~1/4-1/2 mile TR private road ~850' off road

SUBDIVISION NAME S. R. No.

LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil shallow clay

Percolation Rate 2"/4


Topography 4 to 6%

Depth to Water Table 4'

Rock or other impervious formations none obs.

Lot Area ~1/4 ac Lot Line

Basement with Plumbing Well site Basement without Plumbing ___ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓) Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

X Signed: Dale Brian Stone

Proposed System

IMPROVEMENTS PERMIT BY DBHunnicutt, RS

COMMENTS: Drainfield must be installed shallow (12" cover max.) follow contour. No stepdowns in any ditch.

CERTIFICATE OF COMPLETION BY

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

This is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold