4654 59 5494

10896

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sherman Co. Stone DATE June 8, '90 PERMIT NO. IC-A-48pt.

PHONE: Business _____ Home _____

LOCATION 115 S. TR 1138 (Presbyterian Rd.) ~½ mile TL private (dirt) rd. ~ 1000' off road S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

Future Temporary Lot Line 10'X

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soil ps clay trans

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 3


Auto. Dishwasher Yes (✓) No ( ) Topography 15% 4+

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table

Site ~~Suitable~~ S Yes (✓) No ( ) Rock or other impervious formations none obs.

Lot Area 8.6 Ac

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Benchmark Grading

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

Well not installed as of this date. DRH

COMMENTS: Excessive fall on 2nd, 3rd, & 4th trenches necessitated installing earth dams as shown. Distribution system had to be changed accordingly because of shallow cover depth and likelihood of effluent breakout down trench before going to next trench. Single D box used, All 4 lines fed as equal as possible.

CERTIFICATE OF COMPLETION BY _____ DATE 6-8-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold