DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jerry Archer
ADDRESS: ____
APPLICATION DATE ____
DATE EVALUATED: 3-28-07
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: ____
LOCATION OF SITE: 304 Presbyterian Rd
PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	1-4% near tank	0-10	sbk SBrsl						
		10-38	sbk R/Br C	sc/fi sss sp	sc common				.25
		38-48	sbk R C	fr/sow fi sss sp	sc	48			
2	100' from tank	0-10	sbk sl						
		10-40	sbk RC	sc/fi					
		40-48	sbk cl	fr		48			.25
3	Repair area	0-10	sbk sl/scl						
		10-40	sbk RB C	fi					
		40-48	sbk cl	fr sss sp		48			.25
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	Yes
System Type(s)	Conv.	conv
Site LTAR	.25	.25

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: J Melville
OTHER(S) PRESENT: ____
COMMENTS: 56' to tank