06231

Pamela & Charles Edwards 257 Presbyterian Rd 4654-69-2770

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ~~Dale Donahoe~~ DATE 7/5/90 PERMIT NO. IC-A-42

PHONE: Business _____ Home _____

LOCATION 1155 TL 1138 (Presbyterian Rd.) ~ ½ mi TL private road ~1000' off road S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Area of drainfield

No. Bedrooms 3 No. Bathrooms 3

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | clay |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | ~.35 |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | ~10% |
| Site ~~Suitable~~ PS | Yes (✓) | No ( ) | Depth to Water Table | 4'+ |
| Lot Area _____ | | | Rock or other impervious formations | none obs. |


✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement

1000 gal T.

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )




Plot of System

Installed by Bob Mayhew

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Deck

The location of the proposed Deck & Garage addition does not appear to impact the existing septic system.
**NOTE: Any Bldg must be 5ft off Septic System

Marie Dolan REHS
Date: 7/5/2011
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY Sam Ingram EHS DATE 7/5/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold