3:00

06231

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dale Donahue DATE May 22, 89 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 S. TL 1138 (Presbyterian Rd) ~½ mile TL private road ~1000 ft off road. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ OS Yes ( ) No ( )

Lot Area 1.6 AC

Character & Porosity of Soil Area) Iredell clay

Percolation Rate ~35

Topography ~10%


Depth to Water Table 4'+

Rock or other impervious formations none obs.

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement

Lot Line

1000 p.t.



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Dale S Donahue

Pump specs: 29 gal/min at approx. 23' TDH

IMPROVEMENTS PERMIT BY _____ DATE _____

COMMENTS: Start drainfield close to driveway. Fill ST follow contour. 24" trench bottom depth. Use 1½" or 1¼" Sch 40 laterals with one 5/32" hole every 5 feet. 2' pressure head on lines.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold