DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Ray Mozelly OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 10/28/96
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Davidson Downs 124
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
124 1 CONV.	3-4%	0-9	sbk / sl	1:1 / SS NP	PS	PS			.3
		10-18	sbk / cl	1:1 / S P					
		19-44	GR / scl	1:1 / SS SP					
125 2 CH PLASTIC		0-9	sbk / c	1:1 / S SP	PS				
		10-19	sbk / cl	1:1 / SS SP					
		20-30	sbk / scl	1:1 / SS SP					
		31-47	sbk / cl SAP	1:1 / SS NP	PS		PS	PS → .35	
3									
4									
5									

AVAILABLE SPACE (.1945): SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:

EVALUATED BY: OTHER(S) PRESENT:

COMMENTS: