ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Phillips Chatfield APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-16-3

PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: _____

LOCATION OF SITE: Lot 120 Hardison Homes PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-15	Sdy loam w/ cl	fr					PS .3
		15-37	sdy clay l	fr-fi-P					
		37-48	mottled red/brown	w-mw-si-sp, mi-fi-plas					
2		n-d	Sdy loam	fr					PS .35-.3
		4-17	sdy c-l	fr-fi-SSP					
		17-35	wtd/gy clay l	fi-vp (Gleyed layers)					
		35-48	wtd/gy cl	fr-SSP-SPP					
			few brds & lds/gvl						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____