3:30 ✓

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 202835

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4654-87-9435

APPLICANT: GAYLE LINDLY APPLICANT ADDRESS: 143 BUCKINGHAM PLACE RD. (205 Buckingham)

SITE ADDRESS: SAME PHONE: 602-358-0542 ALT. PHONE:

SITE DIRECTIONS: PRESBYTERIAN RD, TR BUCKINGHAM, TL BUCKINGHAM, ON R

SUBDIVISION: DAVIDSON DOWNS SECTION: LOT # 86 LOT AREA: .79AC DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank Ex. 1250 (gal) STB Date
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 4 Linear Ft: 78'
Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth —

☐ New System ☐ Repair ☒ Expansion System Type: I II (III) IV V VI
System Description: PANEL BLOCK
Repair System Description: SAME
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: [redacted] ☐ Public ☒ Community

Comments / Conditions:

Installed as Drawn per plan
First 2 expansion lines got a little deep due to existing ST & drain lines

INITIAL SITE SKETCH

SEE PLAN FROM SOIL & FORESTRY SERVICES

BA

PUT FILTER IN EX. TANK

AS BUILT SKETCH

CHECKED FLOW DIVIDER

BA

CHECKED JUN 10 2014

CHECKED JUN 10 2014

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Gayle Lindly Date: 5-19-14 Installed by: C. Wayne Croisor

IMPROVEMENT PERMIT by: BA APPROVED MAY 19 2014 OPERATION PERMIT by: Maintenance Branch RS Date: 6/12/14

AUTHORIZATION TO CONSTRUCT by: BA APPROVED MAY 19 2014 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK