12542

4654-88-4646

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Deal DATE 7/1/91 PERMIT NO. K-6-A-3

PHONE: Business 892-9999 Home

LOCATION Presbyterian Rd. (SR 1138) 1155 TL Presbyterian, TL on gravel drive before you go down hill to creek S. R. No. 1139

SUBDIVISION NAME Goldstand LOT NO. 3A SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil cl - sa cl
Percolation Rate .35
Topography slightly concave slope
Depth to Water Table >48"
Rock or other impervious formations

Lot Area 20,600 Ft²

____ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3 @ 100 / 135 / 90
Sq. Ft. 1200 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY Wesley Sparks RS DATE 7/1/91

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold