4654-88-4646

IREDELL COUNTY HEALTH DEPARTMENT

12541

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Deal DATE 6/20/91 PERMIT NO. IC-6-A-3

PHONE: Business 892-9999 Home _____

LOCATION Presbyterian Rd, on (L) before creek

S. R. No. _____

SUBDIVISION NAME Goldsland LOT NO. 3B SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	Character & Porosity of Soil: Sand
Auto. Dishwasher	Yes	(✓)	No	( )	Percolation Rate: .3
Auto. Wash. Machine	Yes	(✓)	No	( )	Topography: 2-3%
Site Suitable	Yes	(✓)	No	( )	Depth to Water Table: 74"
					Rock or other impervious formations: No

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4@100
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS DATE 6/20/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold