4654-97-3060

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Norman Shirley DATE 8-25-87 PERMIT NO.

PHONE: Business Home

LOCATION 1155 TL 1138 (Presbyterian Rd) Turn into Davidson Downes Bear Pt at end on Rt S. R. No.

SUBDIVISION NAME Davidson Downes LOT NO. 22 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area ~32000 ft²

Character & Porosity of Soil clay


Percolation Rate ~35 4-6 @ 49"

Topography

Depth to Water Table

Rock or other impervious formations none obs.

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 1030+ Linear Ft. ~250

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Community Well

Installed by H J Erwin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY H J Erwin, RS DATE 8-25-87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold