4654-98-1477

07987

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Honeycutt DATE Aug 10, 88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 S. to 1138 (Presbyterian Rd.) on Rt past Davidson Downes and before creek S. R. No. _____

SUBDIVISION NAME Hillcreek LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20000ft²

Character & Porosity of Soil clay


Percolation Rate 2-35

Topography 2-4%

Depth to Water Table 4ft

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1035 ± Linear Ft. 345 ±

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by A J Erwin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 8-10-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold