1653 Mecklenburg Hwy.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR The Buttery + Beanery DATE 8-25-M PERMIT NO. _____

PHONE: Business 892-1733 Home _____

LOCATION 1/5 South on left before Drive In

_____ S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other 32 Seat Restaurant

No. Bedrooms _____ No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )

Character & Porosity of Soil Clay loam Low to very fair
Percolation Rate not taken
Topography Level to 2% slope
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area Acreage



Size of Tank 1000 Gals
Nitrification Field
No. of Lines 3 300
750 Sq. Ft. [redacted] Linear Ft. [redacted]
Depth of Stone in Lines 24
Water Supply: Individual ( )
Public (✓)
East Park Mobile Home Park water system
Installed by A. C. Hollingsworth

Drive
75' X 100'

Plat of System

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold