IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joe Corriher DATE 8-11-95 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 South TL on 1136

S. R. No. _____


SUBDIVISION NAME Freemont Park LOT NO. 115 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Sandy clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Not taken
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	20% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area Less than ½ acre existing lot



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 660 Linear Ft. 262
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by F.J. Ervin

IMPROVEMENTS PERMIT BY John Howdon

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J.C. Moore DATE 8-11-

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy. Gold