IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Ritchie DATE 8-24-76 PERMIT NO. 233

PHONE Business _____ Home _____

LOCATION 115 South 4 mi. past Drive-In on left

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other 2 mobile Homes

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit: Yes ( ) No (✓)

Auto. Dishwasher: Yes ( ) No (✓)

Auto. Wash. Machine: Yes (✓) No ( )

Site Suitable: Yes (✓) No ( )

Lot Area 1 Acre +

Character & Porosity of Soil sandy clay loam / Porosity good


Percolation Rate Soil borings

Topography 2-3% Slope

Depth to Water Table 10'+

Rock or other impervious formations none

5 ditch 13' X 100' 5 lines



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 1250 Linear Ft. 500

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold