IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Floyd Green DATE 12-12-77 PERMIT NO.

PHONE: Business Home

LOCATION 115 South To on 1136 1st Rd Turn left 1/8 mi on right S. R. No.

SUBDIVISION NAME Freemont Park LOT NO. 127 SECTION OR BLOCK NO. 2


House (✓) Mobile Home ( ) Business ( ) Other (Repair)

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	( )	No	( )

Lot Area 1/2 acre

Character & Porosity of Soil Clay loam Porosity Fa...
Percolation Rate 60 min 1 inch
Topography 4% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank Existing 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 120
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Down spouts + surface water from above lots needs to be run around where Tank + lines are.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 12-13-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold