IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joe Conrider DATE 3-11-15 PERMIT NO. 38

PHONE: Business _____ Home _____


LOCATION 1155 Tl on 1136 1st Lane Rd To Left S. R. No. _____

SUBDIVISION NAME Freemont Park LOT NO. 34 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms	3	No. Bathrooms	2	Character & Porosity of Soil	Sandy loam Good
Garbage Disposal Unit	Yes ( )	No	(✓)	Percolation Rate	1" Taken
Auto. Dishwasher	Yes (✓)	No	( )	Topography	5% Slope
Auto. Wash. Machine	Yes (✓)	No	( )	Depth to Water Table	10'+
Site Suitable	Yes (✓)	No	( )	Rock or other impervious formations	None

Lot Area 18,000 Sq Ft



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 3-11-15

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold