4655 28 2297

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers DATE 3-20-01 PERMIT NO. 49

PHONE: Business 872-4111 Home _____

LOCATION 115 South TL on 134 at 3rd house 1/4 mi TL last

S. R. No. 1134

SUBDIVISION NAME Eloamont Park LOT NO. 17 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2a ons

Character & Porosity of Soil Appling clay (porosity Good)
Percolation Rate 60 min/inch
Topography Some Slope
Depth to Water Table 4ft
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY J. D. Cabriel

COMMENTS: Soil is a appling clay but has a certain amount of sandy to give some porosity. Extra rock in ditch will give more storage and provide more Longitudinal Drainage towards Soil.

CERTIFICATE OF COMPLETION BY J. D. Cabriel DATE 3-30-01

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold