4655283317

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers DATE 5-17-94 PERMIT NO. 115

PHONE: Business 872-4114 Home

LOCATION 115 S TL on 1136 1/2 mi on. left

S. R. No. 1136


SUBDIVISION NAME Fremont Park LOT NO. 16 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ~ 20,000

Character & Porosity of Soil Davidson & Appling Porosity Poor
Percolation Rate 60 min/inch
Topography 2% Slope
Depth to Water Table 18+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 15" to 12"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-19-94

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold