4655284848

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Floyd Green DATE 7-2-96 PERMIT NO. 125

PHONE: Business 464-3414 Home

LOCATION 115 South Th on 115 to Fremont Dr.

S. R. No.

SUBDIVISION NAME Fremont Park LOT NO. 137 SECTION OR BLOCK NO.

Freemont Park - Sec 2 - Lot 137 190 Freemont Loop - Mobil.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 17,200 sq ft


Character & Porosity of Soil clay loam / porosity Fair

Percolation Rate Soil borings

Topography 20% Slopes

Depth to Water Table 12"

Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines

Water Supply: Individual ( )
Public (✓)

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY L C Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY L C Moore DATE 7-2-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold