4655295122

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lyle Lentz DATE 2-26-19 PERMIT NO. 269

PHONE: Business 222-2411 Home _____

LOCATION 115 Tee Ct on left from end of cul-de-sac

S. R. No. _____

SUBDIVISION NAME Emerald Point LOT NO. 108 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes ( ) | No (✓) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Lot Area 2700 Sq Ft

Character & Porosity of Soil Sandy Clay Loam Loamy sand
Percolation Rate 25 min/inch
Topography 2 to 5%
Depth to Water Table 48"+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 24"
Water Supply: Individual ( )
Public (✓)

Installed by Hyde

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Lyle Lentz DATE 2-26-19

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold