DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 2A 4A4
PROPERTY RECORDED: YES
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: ALBERT E TENNENT OWNER: L AGENT: ___ PHONE: 892-4253
ADDRESS: R#11 Box1293 APPLICATION DATE: 8/18/93 DATE EVALUATED: 8/19/93
MOORESVILLE, NC. PROPOSED FACILITY: 3BD - 2BA MOBILE HOME
PROPERTY SIZE: ___
LOCATION OF SITE: OAKRIDGE LN, 1155 T L ON EASTPORT LN TR, TR ON OAKRIDGE LN 2ND ON (L)
WATER SUPPLY: On-Site Well ___ Comm. Well L Public ___ Other ___ EVAL. METHOD: Auger Boring V Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	4-10% IRR LCV	0-4	2/GR SCL	1:1	S	P		NA	
		5-16	2/SBK SCL	1:1	P	P	P	II NS	
		17-29	2/WK SBK SCL	1:1	WSS-WPS	P	P	II NS	
		30-39	3 VWK SBK SCL	1:1	WSS-WP	P	P	II NS	
2									
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .33-.35
EVALUATED BY: Apahs OTHER(S) PRESENT: GENE TENNENT, HERBERT TENNENT
COMMENTS: 36" TRENCH BOTTOM / LINES ON SLOPE CONTOUR