0713

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tony Neville DATE 10-24-88 PERMIT NO. 4655-35-2322

PHONE: Business _____ Home _____

LOCATION 115 S. to 1136 (Faith Rd.) TR into Caldwell Est. on 3rd on left S. R. No. _____

SUBDIVISION NAME LG Caldwell Estates LOT NO. 8 SECTION OR BLOCK NO. _____

J & J LAND & TIMBER

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable PS Yes (✓) No ( )

Lot Area ~5 AC

Character & Porosity of Soil Aroad) Drainfield clay


Percolation Rate 103

Topography 6-10%

Depth to Water Table 34

Rock or other impervious formations none dr.

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

1250 gal. tk.

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 800 Linear Ft. 267

Depth of Stone in Lines 12"

Water Supply: Individual (✓) p-d

Public ( )

Installed by JJ Senior

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Drift Owner

COMMENTS: Alarm tested & working but not mounted.

Landscape over drainfield area.

CERTIFICATE OF COMPLETION BY [signature], R.S. DATE 10-24-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold