07369

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jan Von Lenken DATE Jan. 20, '88 PERMIT NO. 4655-35-2683

PHONE: Business _____ Home _____

LOCATION 1155. TL 1136 (Faith Rd.) ~½ mile TR ~⅛ mile on left S. R. No. _____

SUBDIVISION NAME L. G. Caldwell Estates J & J LAND & TIMBER LOT NO. 7 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Back of lot Yes (✓) No ( )

Lot Area ~5Ac.

Character & Porosity of Soil clay

Percolation Rate 2.3


Topography 6-15%

Depth to Water Table 3'+

Rock or other impervious formations none obs.

1000 gal pump tank

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by A J Erwin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Wet weather occurred before drainfield initially covered. Need to grass over drainfield A.S.A.P.

CERTIFICATE OF COMPLETION BY D K Henson, R.S. DATE 1-20-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold