4655359817

IREDELL COUNTY HEALTH DEPARTMENT

1823

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Faith Presbyterian Church DATE August 3, '90 PERMIT NO. I-D-C-37A

PHONE: Business _____ Home _____

LOCATION 115 S. TR 1136 (Smith Rd.) on Right just before jct. w/ 1137 (Midway LAKE RD) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Upgrading facilities for existing church adding fellowship hall & kitchen Seating capacity of sanctuary Approx 140 (200 proj design flow

No. Bedrooms — No. Bathrooms 4

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3 X 100' 3 X 200' 3'X100'

Character & Porosity of Soil psoln


Percolation Rate 4

Topography 2-4%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

_____ Basement with Plumbing 46'4 Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing (1500) Gals.

Nitrification Field: Adding (3)

No. of Lines _____

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Robert Brawley

IMPROVEMENTS PERMIT BY _____ SR 1136

COMMENTS: Follow contour with new lines, Maximum trench bottom depth of 36". Use D box with speed leveler after setting Bell Run Valve.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold