IREDELL COUNTY HEALTH DEPARTMENT 4655 36 4303

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J & J Land & Timber DATE 6-24-86 PERMIT NO. 360

PHONE: Business _____ Home _____

LOCATION 1125 S Rt on Faith Rd ~3 mile on left at corner of dirt street S. R. No. _____

SUBDIVISION NAME Caldwell Estates LOT NO. 3 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 2 1/4 acre

Character & Porosity of Soil clay loam
Percolation Rate .4 gal/ft²/day
Topography 2-7%
Depth to Water Table 4'+ in septic area
Rock or other impervious formations none obs

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Bowlos

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

DRIVE

IMPROVEMENTS PERMIT BY Faith Rd K.S.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles K. Barnett DATE 6-24-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold