4655 36 6165

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James H. Presson Jr. DATE 12/1/88 Quad PERMIT NO. 21 D

PHONE: Business _____ Home _____

LOCATION 1155 TL 1136 (Faith Rd.) ~ 3/4 mile on Rt. _____

_____ S. R. No. _____

SUBDIVISION NAME L. G. Caldwell Estates LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil Clay
Percolation Rate ~.4
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by R Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Presson DATE 12/1/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James H. Presson Jr. DATE Apr. 8, 87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 S. SR 1136 (Faith Rd.) ~ 3/4 mile on Rt. _____ S. R. No. _____

SUBDIVISION NAME L. G. Caldwell Estates LOT NO. 1 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate 2.4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 4'+
			Rock or other impervious formations none obs.

Lot Area ~1/2 AC

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: James H. Presson, Jr.

IMPROVEMENTS PERMIT BY David R. Hanson, RS.

COMMENTS: Keep system fairly shallow (12-18" over) and follow contour. Landscape area to provide good surface drainage across system.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold