4655457346

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dean Ryles DATE 11-10-82 PERMIT NO. 362

PHONE: Business _____ Home _____

LOCATION 155 S. to 1136 Faith Rd. to 1137 Midway Lake Rd., 1 mile on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam to silty p.m.
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4 Minutes
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4 to 8%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Mod. gullied - filled in
			Rock or other impervious formations	None obs.

Lot Area .9 Ac.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by H. Green

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

The proposed / existing GARAGE addition does not appear to impact the existing septic system.

**NOTE: GARAGE MUST BE MIN 25' FROM WELL

R.S.

Date: 11-10-82
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hanson DATE 11-10-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold