ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Eloise Stewart APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

PROPOSED FACILITY: 3bdrm House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.269 ac

LOCATION OF SITE: Serene Lake #2 PROPERTY RECORDED: _____

WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 4%	0-10	sl gr	fr ss sp		46"			P5 0.3
		10-46	c-sl sbk	fr ss sp					
2		0-12	sl sbk	fr ss sp		48"			P5 0.3
		12-48	c-sl sbk	fr ss sp					
3	Repair	0-5	sl sbk	fr ss sp		43"			P5 0.5
		5-32	c-sl sbk	fr ss sp					
		32-43	sl cb-p sbk	fr ss sp					
		43-	San						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	5	5
System Type(s)	PM-Conv	PM-25% Red
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): P5

EVALUATED BY: _____

OTHER(S) PRESENT: _____