4655525255

13112

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Barbara Black DATE 8/5/91 PERMIT NO. IC-A-440

PHONE: Business _____ Home _____

LOCATION Nance Farm Rd. 1272, 115 S, TL on Midway Lake Rd, TL on Nance Farm Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil PS clay
Percolation Rate 4
Topography 2%
Depth to Water Table > 48"
Rock or other impervious formations none observed

Lot Area acreage

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System Nance Farm Rd.

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2 @ 100' x 3'
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓) Public ( )
well to left of trailer

Installed by Tony Nance

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 8/5/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold