IREDELL COUNTY HEALTH DEPARTMENT 4055551364

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ~~Floyd~~ Floyd Blackwell DATE 2-5-86 PERMIT NO. 37

PHONE: Business _____ Home _____

LOCATION 1155 TL 1136 (Faith Road) ½ mile on R (on R across from 1276 (Moff Road))

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay-loam	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	25 MPI	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Rolling	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	54	
Lot Area	@ 0.57 ACRE		Rock or other impervious formations	NONE OBS.	

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 120 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Floyd Blackwell

Plot of System

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep System Shallow, follow contours

(X) Neighbors' Well

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold