DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Broadmoor Homes OWNER: AGENT: ✓ PHONE: 443-7660
ADDRESS: Po Box 1242 APPLICATION DATE: DATE EVALUATED:
Monroe NC PROPOSED FACILITY: 3BR - 2BA
PROPERTY SIZE: .87 Ac
LOCATION OF SITE: Endwick Hills Lot 2
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-6	wk sbk / c	1:1 F	S	P	P	P (NS-MD, .3-.35)	
	LS	7-13	wk sbk / sic	1:1 F			↓		
	LS	14-26	wk sbk / c-sic	1:1					
	LS	27-42	wk cr. c-SAND	1:1					
2									
3									
4									
5									

AVAILABLE SPACE (.1945): P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE .3-.35
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: ____