DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Gary & Susan Shelton
ADDRESS: Saddle Rd
PROPOSED FACILITY: Residence
LOCATION OF SITE: Saddle Rd
PROPOSED DESIGN FLOW (.1949): 360
APPLICATION DATE: 7-30-07
DATE EVALUATED: 9-17-07
PROPERTY SIZE: _____
PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	15%	0-5	gr scl		Br	48	c-sap		.3
		5-30	sbk C	Cr sss p	Red				
		30-48	sbk cl	Cr sss p	Red				
2	Linear	0-9	Gr sl		Br	48	f-sap		.3
		9-28	mod bk C	Dr sss p	Red				
		28-48	wk sbk C+cl mix	Cr sss p	Red				
3		0-20	scl			20			
		20	L/sc sap						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	yes	yes
System Type(s)	25% red	25% red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: J Melville
OTHER(S) PRESENT: _____

COMMENTS: _____