13346

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR James Campbell DATE 1/10/92 PERMIT NO. IC-9-A-25

PHONE: Business _____ Home 523-4242

LOCATION Beacon Place - 1155 TL Midway Lake - 1 mile TR into Beacon to 1st lot on L

S.R. No. _____

SUBDIVISION NAME Beacon Place LOT NO. 25 SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 20,000 FT²

Soil Characteristics P - C (S, SF) TRANS. MATERIAL


Application Rate .3

Topography P 2%

Depth to Water Table 48"

Rock or other impervious formations S None encountered

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement 1 Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5 @ 90' x 3'

Sq. Ft. 1350 Linear Ft. 450

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by F. Calloway

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY AWS

COMMENTS Soils shallow - at 36" soil becomes nearly massive, very plastic - 24" installation depth to trench bottom maintained. S/T set shallow - DOT spec culvert used to sleeve shallow line under driveway. Lot was heavily graded after permit issued - this is 2WS permit to avoid pump.

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 1/10/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold