N. C. Department of Environment and Natural Resources/Division of Environmental Health

NOTICE OF VIOLATION
ON-SITE WASTEWATER SYSTEM

___**Certified Mail**
(Return Receipt)

___**First Class Mail**

_✓_**Hand Deliver**

Owner Vern & Carole Hensel Mailing Address 106 Beracah Mooresville NC

Occupant same Location same

☒ Residence ☐ Business ☐ Other _____

_____:
(Owner)

You are hereby notified that you are violating the Rules adopted by the North Carolina Commission for Health Services or Article 11 of Chapter 130A of the General Statutes of North Carolina by owning or controlling a residence, place of business, or place of public assembly which is not provided with an approved wastewater system. Your wastewater system is not in compliance.

On 3-23-06, an inspection of the wastewater system by the Iredell County Health Department indicated the following violations:

Violation	Law or Rule Cite
Discharge of Effluent to surface of the ground	15A NCAC 18A.1961 (a)(1)(A)

You are hereby ordered to bring your wastewater system into compliance by completing the following:

☒ Install/Repair wastewater system. You must obtain a Repair Permit from the local health department prior to repair your system.

☒ Other Repairs *(Specify)* possible distribution adjustment

☐ Eliminate wastewater discharge and connect to an approved wastewater system.

☒ Perform Maintenance *(Specify)* possible terralift

If the wastewater violation is not brought into compliance by 4-23-06, appropriate legal action will be taken.

Failure to comply with the laws, rules and this notice will subject you to the following legal remedies; Injunction Relief [G.S. 130A-18], Administrative Penalties [G.S. 130-22(c)], Suspension or Revocation of Permits [G.S. 130-23], and Criminal Penalties [G.S. 130-25].

You may contact our office at 610 E Center, (704-664-3718, phone; _____, fax).

Notice Issued 3-23-06 (Date) Signed Judy Melville (DENR/DEH) Agent

Compliance 5-1-06 (Date) Signed Judy Melville (DENR/DEH) Agent

Tommy Frye
Frye Grading Service

3-23-06 Tommy Frye requested copy of permit to fix failure

3-23-06 Went to site. Verified lower line failing. issued o/or upper lines were drier.

4-11-06 Met on site w/ Tommy Frye, Wesley Sparks. Dug up distribution. D-Box at every line except lowest. w/ speed leveler.

Recommended adjust distribution by removing all D-Boxes except upper line and connect all pipes to one D-Box.

Took soil boring - one auger hole - soil was firm.

Recommended terralift.

Lentz - terralift week of 4-17-06

5-1-06 site visit soil is dry but owners not using full water amount - conserving on clothes washing. May need repair by adding 100' of line - about 3 lines. Waiting for them to decide if will stay on water conservation or