IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 130.00 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 128800 PIN# 4655 61 2361 DATE 6/7/05

OWNER OR CONTRACTOR Robert Morgan PHONE: Business _____ Home _____

ADDRESS 16505 Jetton Rd. Cornelius NC 28031

LOCATION 1155, TL Midway Lk, on Lt across From Beracah Rd

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA 0.341 AC SITE CLASS PS DESIGN FLOW 360 L.T.A.R. 0.3

Septic Tank: 1000 Gallons; STB 1012 Date 8/7/05
Pump Tank: _____ Gallons; PT _____ Date _____
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 600 Linear Feet 200
No Lines 4@50' Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth —

☒ New System ☐ Repair System Type: I, II, (III), IV, V, VI
System Description: Gravity Panel
Repair System Description: LP Panel Block - Limited
Maintenance Agreement Required: ☐ Yes ☒ No (1945c)

☒ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Bathrooms ____
☐ Business No. Employees ____
☐ Other _____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply:
☒ Individual
☐ Public
☐ Community

Comments:/Conditions:

Comments:/Conditions:

INITIAL SITE SKETCH

See Attached Plan By

Rollins Soil + Environmental Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Sara Morgan date 6-8-05 Installed by: Craig Thompson

Improvement Permit by: RS date 6/7/05 Operation Permit by: RS date 3/24/

Authorization to Construct by: RS date 6/7/05 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK