IREDELL COUNTY HEALTH DEPARTMENT

Existing System/Deck

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 156528 PIN # 4655714387.000 DATE 6/5/09

OWNER or APPLICANT Terri Young PHONE: Business 704 230-7700 Home: 704 895-9433

OWNER or APPLICANT ADDRESS 161 Tammy Dr. Mooresville NC 28115

LOCATION / DIRECTIONS Hwy 115 TL Faith Of TR Midway Lake Rd. Th Tammy Dr. 161 Tammy Dr. on Left

SUBDIVISION N/A BLOCK / SECTION LOT # LOT AREA 7.91ac DESIGN FLOW 360 L.T.A.R. .3-.35 Ex's

Septic Tank Ex's 1500 Gallons: STB Date

Pump Tank Gallons: PT Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 3 Linear Feet 400' Ex's

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☐ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: Existing System

Repair System Description:

Maintenance Agreement Required ☐ YES ☑ NO

☐ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 3

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions

Portion of ~8 acres

Comments / Conditions

Large Pond

Scale 1"=40'

INITIAL SITE SKETCH

Septic system shows no visible signs of malfunction and meets all health dept. setbacks.

AS BUILT SKETCH

133' Ex's Drainfield

133'

133'

50

~25'

Support beams 5' min from Tank

Ex's. Deck is ~14' x 58'

The support beams have been moved to be 5' min. from Existing Septic System

Existing Septic tank is under existing Deck

14' Deck

58'

Ex's. House

1/2 Bath garage

Drive way

Midway Rd.

Tammy Dr.

Lake

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Boyd Blackwell Date 6-5-09

Improvement Permit by: Date

Authorzation to Construct by: Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by:

Operation Permit by: Date:

Existing System Inspected by: Anthony Coker Jr. R.S. Date: 6/5/09

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant