DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Alice McGraw
ADDRESS: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___
LOCATION OF SITE: 205 Tammy Dr

APPLICATION DATE ___
DATE EVALUATED: 5/9/08
PROPERTY SIZE: ___
PROPERTY RECORDED: ___

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 10-15% *	0-30	wk sbk C SR	Pr SS sp Sap					PS .3 max 28"
		30-40	wk sbk C	Pr-Fr SS Sap					
		40 – auger restriction @ var			12 rock				
2	L 10-15%	0-48	wk sbk C SR	Pr SSS Sap					PS .3
3	L 5-9%	0-12	m sbk C	A SSS Sap	Many/large quartz				PS .3
		12-32	m sbk C	Pr SS Sp Sap					
		32-48	m sbk C	Pr SSS Sap	Few Com Sap				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	
System Type(s)	25% Red	Same
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Anthony Colwell
OTHER(S) PRESENT: Owner