DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: ID A105
PROPERTY RECORDED: NO
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: BRADLEY HAGAR OWNER: ✓ AGENT: PHONE: 663-0638
ADDRESS: R+1 BOX 667 APPLICATION DATE: 6/23 DATE EVALUATED: 6/23/93
MOORESVILLE, NC PROPOSED FACILITY: 3BD - 2BA MIT - HOUSE
PROPERTY SIZE: ~ 80 ACRES
LOCATION OF SITE: FAITH RD.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	P-4-99	0-4	sbk / c	1:1	VH	P	P	—	
		5-13	sbk / c	1:1	SF	S	P	—	
		14-21	wk gr/sic	1:1	FR	S	P	—	
		21-36	SG / SIC	1:1	SS-FR	P	P	II	
		36-44	SG / SIC T	1:1	SS VFR	P	P	II	.3
2					NO CHANGE IN TEXTURE, STRUCTURE				.3
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: SPARKS OTHER(S) PRESENT: BRAD, SHERRY HAGAR
COMMENTS: REQUIRE TRENCH DEPTH OF 30" - CONTOURS VERY IMPORTANT.

BOOK