DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: James Daniels / Kimberly Knight — APPLICATION DATE: _____
ADDRESS: _____ — DATE EVALUATED: 2-16-07
PROPOSED FACILITY: _____ — PROPOSED DESIGN FLOW (.1949): 360gpd — PROPERTY SIZE: _____
LOCATION OF SITE: Shearers Rd TR Faith on left before Charity Ln — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut — TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Near Driveway Front 2 linear 4-5%	0-11	1gr scl	fr ss/sp	com. manganese	48			.25
		11-40	1sbk PBR c	fr/fi se					
		40-48	1sbk c	fr/fi	few/yel/br may be relic				
			+ sap						
2	Front of House	0-8	1gscl	fr		48			.2
		8-28	1sbk/1abk c	fi slp se					
		28-48	c + com. sap	fr/fi					
3	Repair Back of House	0-8	1gscl		few manganese	48			.25
		8-28	1sbk c	fr ss/sp se					
		28-48	c + sap yellow sap						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
able Space (.1945)	Yes	Yes
em Type(s)	25%	25%
e LTAR	.2	.2

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S Melville
OTHER(S) PRESENT: _____

COMMENTS: _____