Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 OF 1
PIN #: 4656-01-1664
Lot #: PT98
Permit #: 216875
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: STANLEY Z. HOUSTON
Applicant: SAME
Address: 248 REVELL RD.
Date Evaluated: 3/10/2016
Proposed Facility: SFR
Design Flow (.1949) 360
Property Size: 1.6 AC
Location of Site: 174 CROSSRAIL RD.
Property Recorded: YES
Water Supply: [ ] Public [X] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	b PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
AB	LINEAR	0-27	CL,M,SBK	SS					
		27-62	CL,W,SBK	SS			COMM INC		
1	3%				NA	62"	@ 27"	62"+	.35
AB	LINEAR	0-40	CL,M,SBK	SS					
		40-50	CL,W,SBK	SS			COMM INC		
2	3%				NA	50"	@ 40"	50"	.35

Description	Initial System	Repair System
Available Space (.1945)		PS
System Type(s)		G-25% RED
Site LTAR		.35

Other Factors (.1946): NONE
Soil Evaluation By: BEN ALDRIDGE
Others Present: DONNA FORTENBERRY
Site Classification (.1948): PS
Site Evaluation By: BEN ALDRIDGE
Others Present: DONNA FORTENBERRY


CROSSRAIL RD
174
100